

Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment:

Description of Vessel / Assembly: Oil Separators

Models covered:

(Cat I) S-5585-CE, S-5587-CE, S-5588-CE, S-5590-CE, S-5687-CE, S-5688-CE, S-5690-CE, S-5885-CE, S-5888-CE, S-5890-CE

(Cat II) S-1901-CE, S-1902-CE, S-1903-CE, S-1904-CE, S-5692-CE, S-5694-CE, S-5792-CE, S-5794-CE

Conformity and Assessment Procedure Followed

Category	I	II
Module	A	D1
Certificate		US.HTI.120.00
PV.	50-200	150-800

Classified for	Group 2 Gases
Design pressure	31 bar
Maximum Op. Temp	+130° C
Minimum Op. Temp	-15° C

The following transposed European standards and other technical specifications have been used:

UL 207.

Notified Body:

The Notified Body which inspected the manufacturers quality assurance system:




Hartford Steam Boiler International GmbH

P. O. Box 1520
 Frerener Str. 13
 D-49785 Lingen
 Germany

Notified Body identification No. 0871

JULIAN PARKER

Signed:  Director of Engineering Date: 06.9.02
 (Responsible Person - Name and actual Title)