## Danfoss A/S

**Industrial Controls Division** 

Head Office

DK 6430 Nordborg, Denmark

Reg. No: 31 744 Giro: 9 03 54 51

Telefax

International + 45 74 49 09 49

Telex: 50 599 danfoss dk

Telephone

International + 45 74 88 22 22

## **DECLARATION**

Danfoss A/S Industrial Controls Division DK-6430 Nordborg, Denmark

declare under our sole responsibility that the products:

## **KP Pressure Controls**

Type KP1, KP1A, KP1E, KP1W, KP2, KP5, KP5A, KP11, KP15, KP15A, KP15B, KP25, kP35, KP36, KP44.

Code No's 060-xxxx

are classified for fluid group I and II (refrigerants: toxic, non-toxic, flammable and non-flammable) and covered by Article 3, paragraph 3 in The Pressure Equipment Directive 97/23/EC, which means that:

- The products are designed in conformity with good technical practice in one of the member states.
- The products are not allowed to carry the CE mark referring to Directive 97/23/EC.
- An EC-Declaration of Conformity cannot be issued referring to Directive 97/23/EC.
- The products must not be used as safety equipment.

Date 2002-09-24 | Issued by

Ebbe Larsen Technical Service

Elle Lann

Date 2002-09-24 | Approved by

Erik Kristensen Technical Manager

RR5AB102 Edition 2 page 1 of 1